



**RFQ #2303-080422**

**Digester Gas Treatment System Media Replacement**

Addendum/Clarification No. 1

**September 22, 2022**

**Questions:**

1. The pre-bid conference states it will be held at the Jobsite but no address is given. Can you please provide an address for our representative to participate?
  - a. 3700 Enterprise Ave. Hayward, CA
2. The file downloaded is named "Request for Qualifications." Please confirm this is a bid request and there is not a list of pre-qualified primes?
  - a. This is a bid request and not a Request for Qualifications.
3. There was only one document available for download from Builders Exchange. Is this all the information needed to bid? Also, will the addenda or any other communications be posted here?
  - a. The bid packet is the only information needed to bid. This document is the only addendum for this request.
4. Is there an Engineer's estimate?
  - a. There is no Engineer's estimate because we are just replacing media in our H2S and Siloxane vessels.
5. When is the anticipated notice to proceed?
  - a. We will most likely replace the media in one of the H2S and Siloxane vessels shortly after the award of bid. The rest of the media changeouts will happen approximately every 9-11 months with the changeout of one each H2S and siloxane over the next 4 year. First cleaning will be scheduled shortly after the City awards the contract.
6. How long can dumpster(s) to dispose of the spent H2S media remain onsite?
  - a. This should be stated in the specifications. If not, it is preferred that the dumpsters be removed ASAP and not to exceed 30 days. Accommodations may be requested if there are reasons outside the contractor's control requiring additional time.
7. Will both a Siloxane vessel and H2S vessel be given to the Contractor each trip to change out?
  - a. Yes, both will be given to the contractor. The contractor will change one of each H2S and Siloxane vessels every trip.